

RECEIVED  
MAR 23 1967

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

YAMBI  
5493

WATER WELL REPORT ENGINEER

STATE OF OREGON  
(Please type or print)

G-3867

State Well No. 4/3w-34 L  
State Permit No.

(1) OWNER:

Name John Michael Jr.  
Address RT 1 BX 220  
Dayton, Ore.

(2) LOCATION OF WELL:

County Yamhill Driller's well number 71  
1/4 Section 34 T. 45 R. 3W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 103 ft. Gage .250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Torch  
Size of perforations 1/4 in. by 6 in.  
400 perforations from 53 ft. to 103 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement  
Depth of seal 30 ft. Was a packer used? Sand  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: 3/4  
Gravel placed from 30 ft. to 103 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 7 ft. below land surface Date 3/22/67  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 140 gal./min. with 78 ft. drawdown after 8 hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 0  
Depth drilled 103 ft. Depth of completed well 103 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL                   | FROM | TO  |
|----------------------------|------|-----|
| TOP SOIL                   | 0    | 1   |
| Brown Clay with Wood Chips | 1    | 30  |
| Blue Clay                  | 30   | 50  |
| Sand with clay             | 50   | 60  |
| Blue clay                  | 60   | 70  |
| Sand with clay             | 70   | 89  |
| Blue clay                  | 89   | 99  |
| Sand with clay             | 99   | 103 |

Work started 3-1 1967 Completed 3-22 1967  
Date well drilling machine moved off well 3-22 1967

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Blue Water Drilling Co.  
(Person, firm or corporation) (Type or print)

Address RT 1 BX 25 DAYTON, ORE.

Drilling Machine Operator's License No. 337

[Signed] Robert A. Hubbard  
(Water Well Contractor)

Contractor's License No. 417 Date 3-22, 1967