

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from date of well completion.

RECEIVED SEP 21 1965

WATER WELL REPORT

STATE OF OREGON (Please type or print)

YAMH 5674

State Well No. 4/4w-2N

11 D

G 3276

State Permit No.

(1) OWNER:

Name Harry Wicks Address Rte. 1 Box 297, McMinnville, Oregon

(2) LOCATION OF WELL:

County Yamhill Driller's well number 2-3 1/4 10-11 1/4 Section T. 4 S R. 4 W. W.M. Bearing and distance from section or subdivision corner Beginning at S.W. corner 909 ft north then East 660 ft to well.

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [X] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 87 ft. Gage 0.250

(7) PERFORATIONS:

Type of perforator used Torch Perforated? [X] Yes [] No Size of perforations 1/4 in. by 12 in. 160 perforations from 67 ft. to 87 ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Grout & Puddled Clay Depth of seal 1.8 ft. Was a packer used? No Diameter of well bore to bottom of seal 1.4 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [] Yes [X] No Was well gravel packed? [X] Yes [] No Size of gravel: 3/4 Pea Gravel placed from 1.8 ft. to 87 ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 22 ft. below land surface Date 9-4-65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Pump test 200 gal./min. with 25 ft. drawdown after 3 hrs. Artesian flow g.p.m. Date Temperature of water 54 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 136 ft. Depth of completed well 87 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Topsoil (0-3), Brown Clay (3-33), Blue Clay (33-54), Coarse Sand & Fine Gravel (54-82), Blue Clay (82-92), Layers of Blue & Brown Clay (92-107), Red Clay (107-128), Gray Firm Siltstone (128-136)

Work started Aug. 30 1965 Completed Sept. 4 1965 Date well drilling machine moved off of well Sept. 4 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Wilcox Drilling & Pump Co. (Person, firm or corporation) (Type or print)

Address Box 569, McMinnville, Oregon

Drilling Machine Operator's License No. 272

[Signed] James H. Wilcox (Water Well Contractor)

Contractor's License No. 428 Date Sept. 12, 1965