

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
AUG 18 1962
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

YAMH

5952

4/4W-36 A

State Well No.

State Permit No.

(1) OWNER:

Name Douglas Goodrich
Address R2 Box 112
Dayton OR

(2) LOCATION OF WELL:

County Yamhill Driller's well number
NE 1/4 Section 36 T. 4S R. 4W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

8" Diam. from +1 ft. to 115 ft. Gage 7/8
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Touch
Size of perforations 5/8 in. by 6 in.
168 perforations from 55 ft. to 115 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
Depth of seal 20 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/8 pea
Gravel placed from 20 ft. to 115 ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 7/18/62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 530 gal./min. with 90 ft. drawdown after 8 hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>top soil</u>	<u>0</u>	<u>4</u>
<u>Blue clay</u>	<u>4</u>	<u>42</u>
<u>Fine Black sand</u>	<u>42</u>	<u>55</u>
<u>Blue clay</u>	<u>55</u>	<u>100</u>
<u>Coursed and St Brawl</u>	<u>100</u>	<u>112</u>
<u>Blue clay</u>	<u>112</u>	<u>115</u>

Work started 7/3 1962 Completed 7/18 1962
Date well drilling machine moved off of well 7/11 1962

(13) PUMP:

Manufacturer's Name Fairbanks Morse
Type: turbine H.P. 15

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Arrow Drilling & Supplies
(Person, firm or corporation) (Type or print)
Address 729 N Main Merburg OR
Drilling Machine Operator's License No. 82
[Signed] Harlin M. Huffman
(Water Well Contractor)
Contractor's License No. 117 Date 7/22, 1962