WATER WELL REPORT STATE OF OREGON

YAMH 6096

RECEIVED

NOV 3 0 1982

State Well No

45/5w-14bb

WATER RESOURCES DEPT. SALEM, OREGON

		1
r	State Permit No.	

(1) OWNER:	(10) LOCATION OF WELL:
Name Yamhill County	County Yamhill Driller's well number
Address McMinnville Ore. 97128	NW 4 NW 4 Section 14 T. 4S R.5W W.M.
City State	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Edward Grenfell County Park
New Well Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 58 Trace ft.
	Static level 10 ft. below land surface. Date 11/11/82
Rotary Air X Driven Domestic X Industrial Municipal Rotary Mud Dug D Irrigation Test Well Dother D	Artesian pressure lbs. per square inch. Date
☐ Bored ☐ Thermal: Withdrawal ☐ Reinjection ☐	(12) WELL LOG: Diameter of well below casing 6
(5) CASING INSTALLED: Steel X Plastic	Depth drilled 115 ft. Depth of completed well 113 ft.
Threaded □ Welded □	Formation: Describe color, texture, grain size and structure of materials; and show
6" Diam. from 0 ft. to 24 ft. Gauge •25	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
Diam. from ft. to ft. Gauge	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
4" Diam. from 8 ft. to 113 ft. Gauge 160 pvc	Topsoil 0 2
(6) PERFORATIONS: Perforated? ☐ Yes ☐ No	Brown Clay 2 8
Type of perforator used Drill	Cemented Med. Gravels. 8 16
Size of perforations in. by in.	Coarse Grained Gray Basalt. 16 55
150 perforations from 53 ft. to 113 ft.	Firm Gray Shale w/unstable
perforations fromft. toft.	layers. 55 105
perforations from	Unstable Gray Shale w/white
(7) SCREENS: Well screen installed? Yes X No	limestone, Caving Conditions, 105 115
(7) SCREENS: Well screen installed? Yes IN No Manufacturer's Name	
TypeModel No.	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	79
Drawdown is amount water level is lowered	
below static level	
a pump test made? Yes No If yes, by whom?	
Reld: 20 gal/min. with 30 ft. drawdown after 4 hrs.	da ju
20 447 7	
and the state of t	
esian flow g.p.m. Emperature of water 51 Depth artesian flow encountered ft.	
(A) CONCERNICE ON	Work started 11/8/82 19 Completed 11/11/82 19
(9) CONSTRUCTION: Special standards: Yes □ No X Cement Grout	Date well drilling machine moved off of well 11/11/82 19
Well seal—Material used Cellient GTOUT Well sealed from land surface to 24 ft.	Drilling Machine Operator's Certification:
Diameter of well bore to bottom of seal 101 in.	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Aduntally J. William Date 11/12/83
Number of sacks of cement used in well seal	(Drilling Machine Operator)
How was cement grout placed? Hole was clean and dry, ceme	Drilling Machine Operator's License No
grout introduced from bottom up.	Water Well Contractor's Certification:
n erryagan errak pakaka yo banyar ranggan sanggan nganggan nganggan pakéndi ay pokéndén ya sanggan sanggan nganggan ngang	This well was drilled under my jurisdiction and this report is true to
Was pump installed? Yes Type Sub HP 1 Depth 105 ft.	the best of my knowledge and belief.
Was a drive shoe used? Yes X No Plugs Size: location ft.	Name Wilcox Drilling and Pump Co. (Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes X No	Address P. 0. 569 McMinnWill Ore.
Type of Water? depth of strata	Simula Vamanit II) VIII
Method of sealing strata off	[Signed] All Marie Well Contractors
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	Contractor's License No428Date
Gravel placed from ft. to ft.	