

YAMHILL  
6395

WATER WELL REPORT  
STATE OF OREGON

State Well No. 5/3W-6 F  
State Permit No. G-1597

(1) OWNER:

Name Mr. Robert Stockhoff  
Address Dayton, Oregon

(2) LOCATION OF WELL: #1

County Yamhill Owner's number, if any—  
80-A, 1/4 Section 6 T. 5-S R. 3-W W.M.  
Bearing and distance from section or subdivision corner  
300 ft. E. of W. line  
175 ft. S. of N. line  
5-S-3W Sec. 6 Se 1/4 Nw 1/4

TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded

6 5/8 od. Diam. from 0 ft. to 87 ft. Gage 17.02  
" Diam. from ..... ft. to ..... ft. Gage .....  
" Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used cutting torch  
SIZE of perforations 1/4 in. by 12 in.  
..... perforations from 36 ft. to 87 ft.  
2 Rows perforations from 1 ft. apart ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed  Yes  No

Manufacturer's Name ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

CONSTRUCTION:

12" Hole 0- 87 Ft.

Was well gravel packed?  Yes  No. Size of gravel: 1/2 to 3/4  
Gravel placed from 18 ft. to 87 ft.  
Was a surface seal provided?  Yes  No. To what depth: 16-18 ft.  
Material used in seal— cemented

Did any strata contain unusable water?  Yes  No  
Type of water? ..... Depth of strata .....  
Method of sealing strata off .....

(10) WATER LEVELS:

Static level 18 ft. below land surface Date .....  
Artesian pressure ..... lbs. per square inch Date .....

Log Accepted by:

[Signed] Robert L. Stockhoff Date 22 Nov., 1957  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 10 gal./min. with 15 ft. drawdown after 2 hrs.  
Artesian flow ..... g.p.m. Date .....

(12) WELL LOG:

Diameter of well ..... 6 inches.

Depth drilled 87 ft. Depth of completed well 87 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
clay	0	5
brown silt	5	21
blue clay	21	38
consolidated blue sand	38	50
blue clay	50	52
blue green sand silt	52	60
blue sand silt	60	77
blue clay	77	81
blue sand silt some brown spots	81	87

RECEIVED  
DEC 16 1957  
STATE ENGINEER  
SALEM, OREGON

Work started Nov. 8 1957. Completed Nov. 14 1957

(13) PUMP:

Manufacturer's Name .....  
Type: ..... H.P. ....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MEEKER WELL DRILLING  
(Person, firm, or corporation) (Type or print)

Address 2902 Portland Rd. Newberg, Oregon

Driller's well number .....

[Signed] John W. Meeker  
(Well Driller)

License No. 111 Date Nov. 14, 1957