NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

YAMH 6432 NC

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED JUL 25 1973 STATE ENGINEER SALEM OREGON

State Well No. 5S/3W-9
State Permit No. Appl. G-10251

(1) OWNER:
Name Barry Fenner
Address Route 1 Dayton Oregon

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 117 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used torch
Size of perforations 1/4 in. by 6 in.
104 perforations from 103 ft. to 117 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 80 gal./min. with 40 ft. drawdown after 4 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 15 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4
Gravel placed from 25 ft. to 117 ft.

(10) LOCATION OF WELL:
County Yamhill Driller's well number 256
1/4 1/4 Section 9 T. 5S R. 3W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 90 ft.
Static level 60 ft. below land surface. Date 7-9-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 117 ft. Depth of completed well 117 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
top soil	0	2	
brown clay	2	20	
blue clay	20	90	
sand	90	102	
sand & gravel	102	117	

Work started 6-28 1973 Completed 7-9 1973
Date well drilling machine moved off of well 7-10 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert S Albano Date 7-18, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 337

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Blue Water Drilling Co. (Person, firm or corporation) (Type or print)
Address RT 1 BX 75 Dayton, Ore
[Signed] Robert S Albano
(Water Well Contractor)
Contractor's License No. 417 Date 7-18, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119