NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAY 8 1969 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) Ap G-5132
(Do not write above this line) Ap G-5584

YAMH 6439

State Well No. 5/3W-9cb

State Permit No.

(1) OWNER:
Name Joe Hollweck
Address Rt 1 Box 140 Dayton

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☑
10" Diam. from 0 ft. to 100 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Cosch
Size of perforations 1/4 in. by 6 in.
480 perforations from 40 ft. to 80 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 15 ft. below land surface Date 4-1-69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 250 gal./min. with 45 ft. drawdown after 8 hrs.
" " "
" " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Cement
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4
Gravel placed from 20 ft. to 100 ft.

(11) LOCATION OF WELL:
County Yamhill Driller's well number 123
¼ ¼ Section 9 T. 5S R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 140 ft. Depth of completed well 100 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil	0	2	
brown clay	2	25	
blue clay	25	47	
black sand	47	80	
blue clay	80	140	

Work started 3-16 1969 Completed 4-1 1969
Date well drilling machine moved off of well 4-1 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Shelburne Date 5-7, 1969
(Drilling Machine Operator)
Drilling Machine Operator's License No. 337

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Blue Water Drilling Co
(Person, firm or corporation) (Type or print)
Address Rt 1 Box 75 Dayton
[Signed] Robert Shelburne
(Water Well Contractor)
Contractor's License No. 417 Date 5-7, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)