

YAMH  
6441

RECEIVED  
JUL 21 1967

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT ENGINEER  
STATE OF OREGON  
(Please type or print)

State Well No. 5/3w-9  
State Permit No.

(1) OWNER:

Name STAYTON CANNING CO  
Address STAYTON, OREGON

(2) LOCATION OF WELL:

County Yamhill Driller's well number 96  
¼ Section 9 T. 55 R. 3W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

12" Diam. from 0 ft. to 143 1/2 ft. Threaded  Welded  Gage 1/4"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name Johnson Screen  
Stainless Steel Model No.  
Diam. 8" ID Slot size 20 Set from 115 ft. to 140 ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite  
Depth of seal 40 ft. Was a packer used? Sand  
Diameter of well bore to bottom of seal 21 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: 1/8"  
Gravel placed from 40 ft. to 143 1/2 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 90 ft. below land surface Date 7-19-67  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 135 gal./min. with 46 ft. drawdown after 4 hrs.  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 0  
Depth drilled 143 1/2 ft. Depth of completed well 143 1/2 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	2
Brown sandy clay	2	41
Blue clay	41	50
Black sand	50	53
Fine sand & clay	53	67
Blue clay	67	94
Brown clay	94	108
Blue clay	108	111
Gravel	111	140
Blue clay	140	143 1/2

Work started 5-30 1967 Completed 7-19 1967  
Date well drilling machine moved off of well 7-19 1967

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Blue Water Drilling Co  
(Person, firm or corporation) (Type or print)

Address RT 1 BX 75 DAYTON, ORE

Drilling Machine Operator's License No. 464

[Signed] Robert S. Helburn  
(Water Well Contractor)

Contractor's License No. 417 Date 7-19, 1967