

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

**RECEIVED**  
DEC 4 1967  
STATE ENGINEER  
SALEM OREGON

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

YAMH  
6442

State Well No. 5/3w-9

State Permit No.

**(1) OWNER:**

Name STAYTON CANNING CO.  
Address STAYTON, ORE.

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
D  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
10" Diam. from 0 ft. to 139 ft. Gage 1/4"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Perforated?  Yes  No.  
Type of perforator used TORCH  
Size of perforations 6 in. by 1/4 in.  
200 perforations from 40 ft. to 60 ft.  
63/80 perforations from 80 ft. to 139 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WATER LEVEL: Completed well.**

Static level 83 ft. below land surface Date 12-1-67  
Artesian pressure lbs. per square inch Date

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
335 gal./min. with 20 ft. drawdown after 2 hrs.  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Cement  
Depth of seal 20 ft.  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel 3/4  
Gravel placed from 20 ft. to 139 ft.

**(11) LOCATION OF WELL:**

County Yamhill Driller's well number 90  
1/4 1/4 Section 9 T. 55 R. 3W W.M.  
Bearing and distance from section or subdivision corner

**(12) WELL LOG:**

Diameter of well below casing 0  
Depth drilled 139 ft. Depth of completed well 139 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown clay	2	5	
Blue clay	5	39	
Black sand & clay	39	59	
Blue clay	59	80	
Black sand	80	92	
Blue clay	92	95	
Sand & gravel	95	125	
Blue clay	125	139	

Work started 10-25 1967 Completed Dec 1 1967

Date well drilling machine moved off of well Nov 20 1967

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John D. Clow Date Dec 1, 1967  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 464

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Blue Water Drilling Co.  
(Person, firm or corporation) (Type or print)

Address P.O. Box 75 Dayton Ore.

[Signed] Robert J. Helburn  
(Water Well Contractor)

Contractor's License No. 417 Date Dec, 1967