

RECEIVED

WATER WELL REPORT

YAMH 6455

5/3w-9P

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

JUN 16 1961

STATE OF OREGON

State Well No.

State Permit No.

STATE ENGINEER SALEM, OREGON

G2047

(1) OWNER:

Name Robert Ruyie
Address Dayton, Ore.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yield: gal./min. with ft. drawdown after hrs.
Compressor Baller test 140 gal./min. with 55 ft. drawdown after 6 hrs.

(2) LOCATION OF WELL:

County Yamhill Owner's number, if any-
SE 1/4 SW 1/4 Section 9 T. 55 R. 3W W.M.

Bearing and distance from section or subdivision corner

1135.6 ft North
870.4 ft West from

5/4 cor of sec 9.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [X] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 119 1/2 ft. Gage 13#
Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [X] Yes [] No
Type of perforator used Torch
SIZE of perforations 12 in. by 1/4 in. 6
168 perforations from 91 1/2 ft. to 119 1/2 ft.

(8) SCREENS:

Well screen installed [] Yes [] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? [X] Yes [] No Size of gravel: 3/4 P-
Gravel placed from 17 ft. to 119 1/2 ft.
Was a surface seal provided? [X] Yes [] No To what depth? 17 ft.
Material used in seal- Cement Grout & Puddled Clay
Did any strata contain unusable water? [] Yes [] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level ft. below land surface Date
Artesian pressure lbs. per square inch Date

(12) WELL LOG:

Diameter of well 10 inches.

Depth drilled 126 ft. Depth of completed well 119 1/2 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Top Soil, Brown Silty Clay, Blue Silty Clay, Compacted Fine Sand w/wood, Tuff Blue Clay, Fine Black Sand, Sandy Blue Clay, Sand & Gravel, Gravel w/ wood.

Work started May 31 1961 Completed June 5, 61

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILCOX DRILLING CO. (Person, firm, or corporation) (Type or print)

Address P.O. Box 569 McMinnville, Ore.

Driller's well number

[Signed] James H. Wilcox (Well Driller)

License No. 53 Date June 6, 1961