NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
FEB 21 1967
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

YAMH 6500

State Well No. 5/3W-16

State Permit No.

(1) OWNER:
Name Robert Shelburne
Address RT 1 BX 75
Dayton, Ore.

(2) LOCATION OF WELL:
County Yamhill Driller's well number 68
¼ ¼ Section 16 T. 5S R. 3W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☑
8" Diam. from 0 ft. to 74 ft. Gage 1/4"
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☑ Yes ☐ No
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
160 perforations from 54 ft. to 74 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 34 ft. Was a packer used? Sand
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4"
Gravel placed from 34 ft. to 74 ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 5 ft. below land surface Date 2-15-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 200 gal./min. with 60 ft. drawdown after 5 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 74 ft. Depth of completed well 74 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top Soil	0	1
Brown Clay	1	25
Blue Clay	25	~~74~~ 47
Black Sand	47	67
Blue Clay	67	74

Work started 1-15 1967 Completed 2-15 1967
Date well drilling machine moved off of well 2-15 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Blue Water Drilling Co. (Person, firm or corporation) (Type or print)
Address RT 1 BX 75 Dayton, Ore.
Drilling Machine Operator's License No. 337
[Signed] Robert S. Shelburne (Water Well Contractor)
Contractor's License No. 417 Date 2-19, 1967

(USE ADDITIONAL SHEETS IF NECESSARY)