

RECEIVED
 DEC 26 1961
 STATE ENGINEER
 SALEM, OREGON

WATER WELL REPORT
 STATE OF OREGON

YAMH
 6571

State Well No. 5/3W-211
 State Permit No. _____

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

(1) OWNER:
 Name W. L. Dorman
 Address _____

(2) LOCATION OF WELL:
 County _____ Owner's number, if any—
NE 1/4 SW 1/4 Section 21 T. 5 S R. 3 W W.M.
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:
10 " Diam. from 0 ft. to 142 ft. Gage 1/4 Wall
 _____ " Diam. from _____ ft. to _____ ft. Gage _____
 _____ " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
 Perforated? Yes No
 Type of perforator used Torch
 SIZE of perforations 12 in. by 3/8 in. 6
264 perforations from 98 ft. to 142 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:
 Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Was well gravel packed? Yes No Size of gravel: 1 1/2
 Gravel placed from 0 ft. to 142 ft.
 Was a surface seal provided? Yes No To what depth? 20 ft.
 Material used in seal—Cement Grout & Puddled Clay
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 38 ft. below land surface Date 12/1/61
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
 [Signed] W.L. Dorman Date Dec. 21, 1961
 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?

Yield:	gal./min. with	ft. drawdown after	hrs.
"	"	"	"
"	"	"	"
Bailer test	gal./min. with	ft. drawdown after	hrs.
Artesian flow	g.p.m. Date		
Temperature of water <u>51</u> Was a chemical analysis made? <input type="checkbox"/> Yes <input type="checkbox"/> No			

(12) WELL LOG: Diameter of well 16 inches.
 Depth drilled 142 ft. Depth of completed well 142 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	2
Brown Clay	2	26
Silty Brown Clay	26	34
Compacted Fine Sand Bl. Clay	34	55
Blue Clay Comp. Fine Sand	55	65
Blue Clay	65	78
Black Sand	78	86
Sandy Blue Clay	86	106
Gravel & Boulders w/ wood	106	142
Clay	142	?

Work started Nov. 10 1961 Completed Dec. 1 1961

(13) PUMP:
 Manufacturer's Name _____
 Type: _____ H.P. _____

Well Driller's Statement:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILCOX DRILLING CO.
 (Person, firm, or corporation) (Type or print)
 Address P.O. Box 569 McMinnville, Ore.

Driller's well number _____
 [Signed] James H. Wilcox (Well Driller)
 License No. 53 Date 12/1/61, 19____