

RECEIVED JUN 9 1959

WATER WELL REPORT STATE OF OREGON

YAMHILL 6711

State Well No. 5/3W-23H(1) State Permit No. G-1085

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: Delta Culp Name Address Rt. 1 Box 123 Dayton, Oregon

(2) LOCATION OF WELL: County Yamhill Owner's number, if any-- SE 1/4 NE 1/4 Section 23 T.5 S R.3 W. W.M. Bearing and distance from section or subdivision corner

Permit # G-1085

(3) TYPE OF WORK (check): New Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED: 10" Diam. from Top ft. to 28 ft. Gage 31.20#

(7) PERFORATIONS: Perforated? [X] Yes [] No Type of perforator used Acetylene Torch SIZE of perforations 1/4 in. by 6 in. 36 perforations from 17 ft. to 28 ft.

(8) SCREENS: Well screen installed [] Yes [X] No Manufacturer's Name Type Model No. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION: Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Was a surface seal provided? [] Yes [X] No To what depth? ft. Material used in seal-- Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 7 ft. below land surface Date 5-16-59 Artesian pressure lbs. per square inch Date

Log Accepted by: [Signed] Delta Culp May 25, 1959 (Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test No gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 57 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG: Diameter of well 10 inches. Depth drilled 28 ft. Depth of completed well 28 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Sandy Top Soil (0-2), Yellow Clay (2-7), Coarse Gravel & Sand (7-28).

Work started 5-12-59 19 Completed 5-16-59 19

(13) PUMP: Manufacturer's Name Type: H.P.

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME Emil O. Beier (Person, firm, or corporation) (Type or print) Address 7555 O'Neil Rd. Salem, Oregon Driller's well number 495 [Signed] Emil O. Beier (Well Driller) License No. 89 Date 5-16-59, 19