

RECEIVED
JUL 6 1959

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

YAMH
6720

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. 5/3W-230 (1)
State Permit No. G-1354

(1) OWNER: A.
Name Curtis Douglas
Address Dayton, Oregon

(2) LOCATION OF WELL:
County Yamhill Owner's number, if any—
S.W. 1/4 S.E. 1/4 Section 23, T. 5, S. 3R. 3, W. W.M.
Bearing and distance from section or subdivision corner
1080 Ft. N. & 640 Ft. E. of the S.W. Corner
G-1354

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
10" Diam. from Top ft. to 68" ft. Gage 31.20
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used XXXXXX Torch
SIZE of perforations 1/4 in. by 6 in.
86 perforations from 47 ft. to 68 ft.
42 perforations from 23 ft. to 34 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name
Type Model No.
Slot size Set from " ft. to " ft.
Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel:
Gravel placed from " ft. to " ft.
Was a surface seal provided? Yes No To what depth? " ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 13 ft. below land surface Date 6-15-59
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Curtis Douglas Date June 18 1959
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Beier
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 56 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 10 inches.
Depth drilled 68 ft. Depth of completed well 68 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	2
Yellow Clay	2	12
Big Gravel & Sand (Water)	12	34
Blue Clay	34	49
Black Sand & Gravel	49	51
Blue Clay	51	68

PUMP TEST
140 G.P.M. @ 22 ft.
200 G.P.M. @ 24 ft.
225 G.P.M. @ 28 ft.
250 G.P.M. @ 28 ft.
275 G.P.M. @ 31 ft.
300 G.P.M. @ Max.

Work started 6-2-59 19 Completed 6-15-59 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Emil O. Beier (Person, firm, or corporation) (Type or print)
Address 7555 O'Neil Rd. Salem
Driller's well number 498
[Signed] Emil O. Beier (Well Driller)
License No. 89 Date 6.15.59 19