

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT MAY 6 1965 STATE ENGINEER SALEM OREGON

STATE OF OREGON (Please type or print)

YAMH 6725

State Well No. 5/3W-24N

State Permit No.

(1) OWNER:

Name Arnold Hildebrandt Address RT 1 Box 116 Dayton, Ore.

(2) LOCATION OF WELL:

County Yamhill Driller's well number 18 S.W. 1/4 S.W. 1/4 Section 24 T. 55 R. 3W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 39 ft. Gage Threaded [] Welded [x]

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Torch Size of perforations 1/4 in. by 152 perforations from 196 ft. to 29 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

CONSTRUCTION:

Well seal—Material used in seal cement grout Depth of seal 18 ft. Was a packer used? [x] No Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 5 ft. below land surface Date 4-22-65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Driller Yield: 1300 gal./min. with 7 ft. drawdown after 2 hrs.

(12) WELL LOG:

Diameter of well below casing 10" Depth drilled 40 ft. Depth of completed well 40 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Sandy silt (0-15), Sand & Med. Gravel (15-38), Coarse Gravel (38-40)

Work started 4-17 1965 Completed 4-22 1965 Date well drilling machine moved off of well 4-22 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME Blue Water Drilling (Person, firm or corporation) (Type or print) Address RT 1 Box 75 Dayton, Ore. Drilling Machine Operator's License No. 417 [Signed] Robert S. Albrecht (Water Well Contractor) Contractor's License No. 417 Date 5-3 1965