NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 26 1968 STATE ENGINEER

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

YAMH 6747 6-6366

State Well No. 5/3W-28

State Permit No.

(1) OWNER:
Name John E. Bauer
Address RT 1 BX 162 Dayton, Ore.

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
8" Diam. from 0 ft. to 135 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used Torch
Size of perforations 1/4 in. by 6 in.
240 perforations from 100 ft. to 130 ft.
120 perforations from 50 ft. to 70 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 54 ft. below land surface Date April 15-68
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Driller
Yield: 400 gal./min. with 26 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used cement
Depth of seal 20 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☐ Yes ☑ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4
Gravel placed from 20 ft. to 135 ft.

(11) LOCATION OF WELL:
County Yamhill Driller's well number 97
¼ ¼ Section 28 T. 5S R. 3W W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 135 ft. Depth of completed well 135 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown Clay	2	25	
Blue Clay	25	50	
Black Sand	50	69	
Blue Clay	69	105	
Sand & gravel	105	124	
Blue Clay	124	135	

Work started April 5 1968 Completed April 15 1968
Date well drilling machine moved off of well April 13 1968

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert S. Albaugh (Drilling Machine Operator) Date April 19, 1968
Drilling Machine Operator's License No. 337

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Blue Water Drilling Co (Person, firm or corporation) (Type or print)
Address Rt 1 Box 75 Dayton Ore
[Signed] Robert S. Albaugh (Water Well Contractor)
Contractor's License No. 417 Date April 19, 1968

(USE ADDITIONAL SHEETS IF NECESSARY)