

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

YAMH  
6821

WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

RECEIVED

MAY 11 1967

STATE ENGINEER  
SG-3957

State Well No. 5/4w-1 L  
State Permit No.

(1) OWNER:

Name O. C. Yocom, Jr.  
Address 609 E. 13th  
McMinnville, Ore.

(2) LOCATION OF WELL:

County Yamhill Driller's well number 73  
1/4 Section 1 T. 55 R. 4W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
Rotary  Cable  Dug  Driven  Jetted  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded  Welded  1/4"  
10" Diam. from 0 ft. to 179 ft. Gage  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Torch  
Size of perforations 1/4 in. by 6 in.  
800 perforations from 99 ft. to 179 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement  
Depth of seal 20 ft. Was a packer used? sand  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: 3/4"  
Gravel placed from 20 ft. to 179 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 10 ft. below land surface Date 5-5-67  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 700 gal./min. with 40 ft. drawdown after 8 hrs.  
" " " " "  
" " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 0  
Depth drilled 179 ft. Depth of completed well 179 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
Brown clay	1	10
Blue clay	10	25
sand & gravel	25	120
Blue clay	120	150
Cemented gravel	150	169
Blue clay	169	179

Work started 3-17 1967 Completed 5-5 1967  
Date well drilling machine moved off of well 5-1 1967

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Blue Water Drilling Co.  
(Person, firm or corporation) (Type or print)  
Address RT 1 Box 25 Dayton Ore  
Drilling Machine Operator's License No. 337  
[Signed] Robert S. Hubbard  
(Water Well Contractor)  
Contractor's License No. 417 Date 5-7, 1967