NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT EIVED

STATE OF OREGON OCT 2 4 1975 State Well No. 55,

(Please type or print)

(Do not write above this line) RESOURCES DELET Permit No. SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Elmer Sharer	County Yamhill Driller's well number C/657		
Address Rt./Box 207		R. /W W.M.	
McMinnville, Oregon 97128	Bearing and distance from section or subdivisi		
(2) TYPE OF WORK (check):			
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	70II	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	69	
Rotary Driven Domestic Lindustrial Municipal Domestic	97	0/00/75	
	Detailed to the second state of	surface. Date 2/2/17	
**************************************	Artesian pressure Ibs. per squar	e inch. Date	
10 Diam from 0 ft to 86 ft Gage 250	(12) WELL LOG: Diameter of well i		
10 " Diam. from 0 ft. to 86 ft. Gage 250	400		
"Diam. from ft. to ft. Gage ft	Depth drilled 100 ft. Depth of completed well 100 ft.		
	Formation: Describe color, texture, grain size and show thickness and nature of each stratus		
DEDECOR A MICONG	with at least one entry for each change of forma	tion. Report each change in	
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal water-bearing strata.	
Type of perforator used Torch Cut	MATERIAL	From To SWL	
Size of perforations 1 in. by 6 in.	Topsoil	0 4	
130 perforations from 68 ft. to 84 ft.	Brown clay	4 23	
perforations from ft. to ft.	Grey clay	23 41	
perforations from ft. to ft.	Dark grey clay	41 45	
(7) SCREENS: Well screen installed?   Ves Ed No.		45 68	
Teb Mi 110	Black sand&small gravel	68 71	
Manufacturer's Name	Brown clay&gravel	71 79	
Type Model No Diam Slot size Set from ft. to ft.	Medium sand&gravel	79 85	
Diam. Slot size Set from ft. to ft.  Diam. Slot size Set from ft. to ft.	Brown clay&gravel	85   88	
Dient Size Set Irojii It. to It.	Grey clay	88 100	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? □ Yes 图No If yes, by whom?			
Trail.			
" " "			
Bailer test 200 gal./min. with 60 ft. drawdown after 1 hrs.			
Artesian flow g.p.m.			
rerature of water Depth artesian flow encountered ft.	Work started 9/29/75 19 Complete	ed 10/2/75 19	
(9) CONSTRUCTION:	Date well drilling machine moved off of well	10/2/75 19	
Well seal—Material usedCement	Drilling Machine Operator's Certification:		
Well sealed from land surface to 23 ft.	This well was constructed under my direct supervision.		
Diameter of well bore to bottom of seal	Materials used and information reported best knowledge and belief.	above are true to my	
Diameter of well bore below seal		Date 10/4/75 <sub>19</sub>	
Number of sacks of cement used in well seal17 sacks	(Driffing Machine Operator)		
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No. 310		
Brand name of bentonite	Water Wall Contract of Contract Contract of Contract o		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? 🗍 Yes 📗 No Plugs Size: location ft.	The state of the s		
Did any strata contain unusable water?   Yes   No	Name Corvallis Drilling Co. Inc. (Type or print)		
Type of water? depth of strata	Address 3440 SW 3rd St. Convallis, Oregon 97330		
Method of sealing strata off	1 1 1 1 1		
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	[Signed] Selanesel H Masself (Water Well Contractor)		
Gravel placed from ft. to ft.		10/4/75 19	
	, Date	, 1J	