

WATER WELL REPORT  
STATE OF OREGON

RECEIVED

YAMH

SEP 7 1984

7272

WATER RESOURCES DEPT  
SALEM, OREGON

State Well No. 55/SW-9db

State Permit No.

(1) OWNER: Well No. 2  
Name Seild S. E. Ind. Land Developers

Address 5516 S. E. Int. Way  
City Milwaukie, Or. 97222 State

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary Air  Driven  Domestic  Industrial  Municipal   
Rotary Mud  Dug  Irrigation  Test Well  Other   
 Bored  Thermal  Withdrawal  ReInjection

(5) CASING INSTALLED: Steel  Plastic   
Threaded  Welded   
6" Diam. from Plus ft. to 18" ft. Gauge 160 PVC

LINER INSTALLED:  
4" Diam. from 0" ft. to 183" ft. Gauge

(6) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot Size Set from ft. to ft.  
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Field: gal./min. with ft. drawdown after hrs.  
Air test 15 gal./min. with drill stem at 183 ft. 1 hrs.  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water 51 Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes  No   
Well seal—Material used Cement Grout  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 10 1/2 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 6 sacks  
How was cement grout placed? Hole was clean & dry, grout introduced from bottom up.  
Was pump installed? NO Type HP Depth ft.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:  
County Yamhill Driller's well number  
NW 1/4 SE 1/4 Section 9 T. 5S R. 5W W.M.  
Tax Lot # 5509-100 Lot Blk Subdivision  
Address at well location: Rte 3, McMinnville, muddy valley road

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 90 Ft. trace ft.  
Static level 20 ft. below land surface. Date 8-10-84  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6 IN.  
Depth drilled 183 ft. Depth of completed well 183 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	1	
Brown Clay	1	3	
Weathered brown & gray basalt	3	8	
Coarse grained gray basalt w/ white streaks of Quartz	8	183	

Work started 8-8-84 19 Completed 8-10-84 19  
Date well drilling machine moved off of well 8-10-84 19

(unbonded) Water Well Constructor Certification (if applicable):  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19\_\_\_\_

Bonded Water Well Constructor Certification:  
Bond 28046279 Issued by: Western Surety  
(number) Surety Company Name  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Wilcox Drilling & Pump Co. (Type or print)  
Address P. O. Box 569, McMinnville, Or. 97128  
[Signed] Randal T. Wilcox Water Well Constructor  
Date 8-11-84, 19\_\_\_\_

NOTICE TO WATER WELL CONSTRUCTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.